

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 7515-0531:114

Page 1 of 1

CATEGORY: Pipe/Fittings

LISTEE: Victaulic, 4901 Kesslersville Rd, Easton, PA 18040
Contact: Mike John (610) 559-3300 FAX (610) 923-3095

DESIGN: Model 922 rubber gasketed mechanical tee fitting for 1¼, 1½, 2 and 2½ inch size piping systems having a rated working pressure of 175psi. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, part size, working pressure and UL label.

APPROVAL: Listed as fittings for fire sprinkler systems. Refer to listee's Installation Instruction Manual for details.

08-04-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

AUGUST 4, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager